

LOCATION 1128 S. Edgemont Dr. CITY GASTONIA
BETWEEN Fair Field Dr. STREET & Woodland Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>105'</u>	<u>5-7-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>100'</u>			

ENTERS 1128 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 357' S of C of FairField Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RLC
MAIN-SIZE 2" C I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993
DEPTH 3 FT 0 IN LOCATION 13' E of C of Edgemont Dr.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 LR # 294706

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY