

LOCATION 1131 Edgemont Ave CITY GASTONIA
BETWEEN Fairfield Dr STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>36'</u>	<u>6-18-94</u>		
MAIN TO PROP. LINE				<u>Tie over Existing</u>		<u>101' 3/4</u>
PROP. LINE TO BLDG.			<u>137'</u>	<u>to 2" Plastic Main</u>		

ENTERS: BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 462' south of Fairfield

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes
MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 30 Ft. In. LOCATION 13 East of Edgemont

"A" P/S READING P. TOTAL ANODES 1* 17 * L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY