

LOCATION 1136, 1136 1/2, 1140 EdgemontCITY GASTONIABETWEEN WOODLAND DRSTREET & Fairfield

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>2'</u>	<u>6-11-94</u>	<u>tied over 4' 10" of 3/4 P. Sn.</u>	
MAIN TO PROP. LINE					<u>to Ext 2" P. Main</u>	
PROP. LINE TO BLDG.						


ENTERS: 1136BRANCHED INTO: 1136 1/2, 1140TAP SIZE: 1/2

PRESSURE _____ P.S.I. _____ INCHES W.C.

LOCATION 13' E of Cap
EdgemontPRESSURE TEST: @ 100 psi For 1/4 Hrs. By JPMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION _____

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY