


LOCATION 1007 EDGEWOOD CIR. CITY EASTBETWEEN Ninth st. STREET & Tenth st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>69'</u>			<u>4-4-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>61'</u>			

ENTERS: SAME BRANCHED INTO:TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 166' From @ ofNinth st.PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY WHLMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1977DEPTH: 3 FT 0 IN. LOCATION West side of Edgewood Cir."A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY