

LOCATION 196 Edgewood Rd. CITY Gastonia
BETWEEN Bates Ln. STREET & Delmont Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	140'	2-11-95		
MAIN TO PROP. LINE	3/4"	P	35'			
PROP. LINE TO BLDG.	3/4"	P	105'			

ENTERS: 196 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 158' S. of center of
OAKS LN.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFSHULTZ

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1964

DEPTH: 3 Ft. In. LOCATION 14' E. of center of Edgewood Rd.

"A" P/S READING 1.5 TOTAL ANODES 1# 0 17# 0 L.R. # 62274

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY