

LOCATION 805 Edwards CITY Gastonia  
BETWEEN Church STREET & Dagland STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>74'</u>	<u>11/26/97</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>69'</u>			

ENTERS: 805 BRANCHED INTO  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SE  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996  
DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — I.R. # 809128

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Plastic</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY