


LOCATION 427 Edwin St CITY GASTONIA
 BETWEEN Edwin STREET & South Side STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>212</u>	<u>5-3-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>"</u>	<u>0</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>"</u>	<u>212</u>			

 ENTERS 427 Edwin St BRANCHED INTO 425 Edwin St
 TAP SIZE 3/4 PRESSURE 60 PSI 3/4 INCHES WC LOCATION BACK - SOUTH EAST
Side of House # 427
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. COOK
 MAIN-SIZE 3/4 C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1983
 DEPTH 2 FT IN LOCATION 372' South of Center of South Side
 "A" P/S READING N/A TOTAL ANODES 1# 17# LR #
 REMARKS RAN New Plastic Service OFF 425 Edwin St



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	