

LOCATION 212 Eight Ave. CITY Crst.

BETWEEN Gibbons st. STREET & South st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>3' TIE OVER.</u>			<u>3-24-97</u>
MAIN TO PROP LINE	<u>"</u>	<u>"</u>				
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>				

ENTERS: SAMP BRANCHED INTO: 214 Eight Ave.

TAP SIZE. 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 131' from @ of Eight Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY ADH

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED \_\_\_\_\_

DEPTH: 3 FT 0 IN. LOCATION West side of Gibbons st.


"A" P/S READING P. TOTAL ANODES 1# - 17# - LR # -

REMARKS:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY