

LOCATION 410 E. 8TH AVE. CITY PAS.T.

BETWEEN UNION RD. STREET & DEAD END. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>59'</u>			<u>2-18-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>57'</u>			

ENTERS: SAME BRANCHED INTO: 408 E 8TH AVE.

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION ' FROM @ OF

E. 8TH AVE.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION NORTHSIDE OF E 8TH AVE.

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY