

LOCATION 502 E. 8TH AVE. CITY GAST.

BETWEEN Union Rd. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>72'</u>		<u>2-18-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>69'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 565' From @ OF
Union Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DWA

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN. LOCATION North side of E. 8TH AVE.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY