

LOCATION 605 E. 8TH AVE. CITY PAS7.

BETWEEN Dead End STREET & Union Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>114</u>			<u>2-21-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>36</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>78</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION from Dead End


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY ICM

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT 3 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY