

LOCATION 608 E. 8TH AVE. CITY AST.

BETWEEN Dead End STREET & Union Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>33</u> '			<u>2-20-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>1</u> '			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>32</u> '			

ENTERS: SAME BRANCHED INTO: 606 E. 8TH AVE.

TAP SIZE. 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 236' From Dead End

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DHJ

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH. 3 FT. 4 IN. LOCATION Nor 1/2 side of E. 8TH AVE.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<b>S</b>		
P/S Pipeline Lead - White Existing Main	<b>E</b>		

