

LOCATION 926 E. 8TH Ave. CITY EAST.  
BETWEEN Dogwood STREET & Reid St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>154'</u>		<u>11-</u>	<u>10-97</u>
MAIN TO PROP. LINE	<u>.</u>	<u>"</u>	<u>33'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>121'</u>			

ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 38' From GOF  
Dogwood Ave

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997  
DEPTH: 3 FT. 0 IN LOCATION S. OF E. 8TH Ave.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY