

LOCATION 1005 E. 8TH. AVE. CITY Gast.

BETWEEN Dogwood STREET & Laurel Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>114'</u>		<u>11-</u>	<u>7-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>7'</u>			
PROP LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>107'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 142' From Bldg

Dogwood


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION S. OF E. 8TH. AVE.

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		