

LOCATION 141 BLG B @ W. 8<sup>TH</sup> ST. CITY Castoria  
BETWEEN South St. STREET & Broad St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>147'</u>	<u>1-25-96</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>107</u>			

ENTERS: 141 BLG B BRANCHED INTO: —  
TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 11' N. of C of W. 8<sup>TH</sup> ST.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP  
MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1976  
DEPTH: 3 Ft. 0 In. LOCATION —

"A" P/S READING .950 TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY