

LOCATION 204 W. 8TH AVE. CITY CAS.

BETWEEN South St. STREET & STREET

|                    | SIZE        | TYPE      | LENGTH      | INSTALLED | RETIRED | RENEWED        |
|--------------------|-------------|-----------|-------------|-----------|---------|----------------|
| MAIN TO BLDG.      | <u>3/4"</u> | <u>P.</u> | <u>102'</u> |           |         | <u>3-21-97</u> |
| MAIN TO PROP. LINE | <u>"</u>    | <u>"</u>  | <u>43'</u>  |           |         |                |
| PROP. LINE TO BLDG | <u>"</u>    | <u>"</u>  | <u>55'</u>  |           |         |                |

ENTERS: SAMP BRANCHED INTO:

TAP SIZE. 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 128' From E of South St.


PRESSURE TEST @ 100 PSI FOR 14 HRS BY MM

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH 3 FT. 0 IN LOCATION Southside of 8th Ave.

"A" P/S READING P. TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



| Test Station                               |          |       |
|--|----------|-------|
| Reading & Location                         | Lead     | Volts |
| P/S Pipeline Lead - Red<br>New Service     | <b>S</b> |       |
| P/S Pipeline Lead - White<br>Existing Main | <b>E</b> |       |

ENG. DEPT. USE ONLY