


LOCATION 207 W 8TH AVE. CITY Cast.BETWEEN South st. STREET & Gibbons st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P.</u>	<u>43'</u>			
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>13'</u>			
PROP. LINE TO BLDG	<u>"</u>	<u>"</u>	<u>30'</u>			

ENTERS: SAME BRANCHED INTO:TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 170' from @ ofSouth st.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN LOCATION southside of 8th Ave."A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY