

LOCATION 503 W EIGHTH AV

CITY GAST

BETWEEN JACKSON

STREET &amp;

DEAD END

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	34'		4-18-97	
MAIN TO PROP. LINE			2			
PROP. LINE TO BLDG.			32			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4

PRESSURE 60 PSI

INCHES W.C.

LOCATION 28' South From (C) of 8th AV

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY Jm

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997


DEPTH: 3 FT 0 IN LOCATION South Side OF 8th

"A" P/S READING P

TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY