

LOCATION 506 8th AVCITY GASTBETWEEN JACKSONSTREET & DEAD END

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>93</u>		<u>4-18-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>56</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>37</u>			

ENTERS: SAME


BRANCHED INTO:

TAP SIZE: 3/4PRESSURE 60 PSI

INCHES W.C

LOCATION 28 South from (C) of 8thPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY QMVMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN. LOCATION South side of 8th"A" P/S READING PTOTAL ANODES 1# ~ 17# ~L.R. # ~

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY