

LOCATION 510 W. 8th AVE CITY CAS

BETWEEN JACKSON ST STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>110</u>		<u>4-22-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>57'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>53</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 29' south from C of W


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY JD

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN. LOCATION South side of 8th

"A" P/S READING P TOTAL ANODES 1# — 17# ~ L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY