

LOCATION 511 W. EIGHTH AVCITY GASTBETWEEN JACKSONSTREET & DEAD END

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>45'</u>		<u>4-21-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>43'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI       INCHES W CLOCATION 27 South From (C) of 8thPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY QmMAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC X YEAR INSTALLED 1997DEPTH: 3 FT 0 IN LOCATION South Side of 8th Av"A" P/S READING PTOTAL ANODES 1# — 17# —L.R. # —

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY