

LOCATION 512 W 8th AVE CITY CASST

BETWEEN JACKSON STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>98'</u>		<u>4-24-97</u>	
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>53'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>45'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 21 South From (C) OF 8th


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY Qm

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION South side of 8th

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY