


LOCATION <u>2962 Elder Ct.</u>		CITY <u>Canton, OH</u>	
BETWEEN <u>Kennett Ave</u>		STREET & <u> </u> STREET	
	SIZE	TYPE	LENGTH
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>61'</u>
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>61'</u>
ENTERS <u>2962</u>		BRANCHED INTO <u>2963</u>	
TAP SIZE <u>3/4"</u>	PRESSURE <u>60</u> PSI	INCHES W C <u> </u>	LOCATION <u>58' N. of center of Elder Ct.</u>
PRESSURE TEST @ <u>100</u> PSI FOR <u>1/4</u> HRS BY <u>S.G.</u>			
PIPE SIZE <u>3/4"</u>	C I <u> </u>	BARE STEEL <u> </u>	COATED STEEL <u> </u>
		PLASTIC <u>✓</u>	YEAR INSTALLED <u>1999</u>
DEPTH <u>2</u> FT	<u>0</u> IN	LOCATION <u>5' E. of center of Elder Ct.</u>	
"A" P/S READING <u>P</u>		TOTAL ANODES 1# <u>0</u> 17# <u>0</u>	LR # <u>983016</u>
REMARKS			



Test Station		
Reading & Location	Lead	Volts