

LOCATION 2974 Elder CT CITY Gastonia
 BETWEEN Kennell Ave STREET & Cultusack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>174'</u>	<u>3-31-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>61'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>73</u>			

ENTERS. BRANCHED INTO
 TAP SIZE 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 265' N of C of
Kennell Ave

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JS
 MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1999
 DEPTH 3 FT 0 IN LOCATION 35' W of C of Elder CT

"A" P/S READING NA TOTAL ANODES 1# 17 # 1 LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>

