

LOCATION	2987 Elder Ct.		CITY	Gastonia		
BETWEEN	Kennett Ave.		STREET &	Heritage Commons Ln.		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	70	10-14-99		
MAIN TO PROP LINE	3/4	P	10			
PROP LINE TO BLDG	3/4	P	60			
ENTERS	2987 Elder Ct.		BRANCHED INTO		0	
TAP SIZE	1/2	PRESSURE	60	PSI	0	INCHES W.C.
		LOCATION				

PRESSURE TEST	100	PSI	FOR	1/4	HRS	BY	MM
MAIN SIZE	2"	C I		BARE STEEL		COATED STEEL	
				PLASTIC	✓	YEAR INSTALLED	1998
DEPTH	3	FT	6	IN	LOCATION		

"A" P/S READING	Plastic	TOTAL ANODES 1#	17#	LR #
-----------------	---------	-----------------	-----	------

REMARKS

	Test Station	
	Reading & location	Lead
	P/S Pipeline Lead Red New Service	S Plastic
	P/S Pipeline Lead White Existing Main	E