

LOCATION 304 Eleventh Ave.CITY East.BETWEEN Hillside Dr.STREET & Edgewood Cir

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>3' TIE OVER</u>		<u>4-</u>	<u>7-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>				
PROP LINE TO BLDG.	<u>"</u>	<u>"</u>				

ENTERS: SAMP

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 100 PSI \_\_\_\_\_ INCHES W C LOCATION 91' From @ of Eleventh  
PVC.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.N.IMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN. LOCATION Westside of Edgewood Cir"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY