

COPY

LOCATION 1247 Elgin Ct. CITY San Antonio
 BETWEEN Fenwick Hall STREET & White Pond Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>85'</u>	<u>9-29-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>8'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>77'</u>			

ENTERS 1247 BRANCHED INTO 0
 TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 107' Soft of Plantation TRK.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1985

DEPTH 3 FT 0 IN LOCATION 18' Soft of Elgin Ct.

A P/S READING Plastic N/A TOTAL ANODES 0 1200 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>