


LOCATION 2341 Elizabeth Cir. CITY CastoniaBETWEEN Mills St. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	92'	2-10-96		
MAIN TO PROP. LINE	3/4"	P	30'			
PROP. LINE TO BLDG.	3/4"	P	62'			

ENTERS: 2341 BRANCHED INTO:TAP SIZE: 1/2 PRESSURE 40 P.S.I. _____ INCHES W.C. LOCATION 45' W. of center of Mills St.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HuffstuffyMAIN-SIZE 3" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1954DEPTH: 3 Ft. 0 In. LOCATION 11' N. of center of Elizabeth Cir"A" P/S READING .9 TOTAL ANODES 1* 0 17* 0 L.R. # 55917

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY