

LOCATION 2342 Elizabeth Cir CITY Gastonia
BETWEEN Mills St STREET & Francis St STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>85'</u>	<u>3-13-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>75'</u>			

ENTERS 2342 BRANCHED INTO
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 38' W of center of Mills St

PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.
MAIN-SIZE 3 C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED
DEPTH 3 FT 0 IN LOCATION 11' N. of center of Elizabeth Cir

"A" P/S READING .9 TOTAL ANODES 1# 0 17# 0 LR # 189678

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	