

LOCATION 1507 Elkhart Cir CITY Gastonia
BETWEEN Elkhart Cir. STREET & Hoffman Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	130'	2-8-01		
MAIN TO PROP LINE	3/4"	P	42'	"		
PROP LINE TO BLDG	3/4"	P	88'	"		

ENTERS 1507 Elkhart Cir. BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 204 West


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.R. of center of Elkhart cir.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 2' FT 6" IN LOCATION 19' south of center of Elkhart cir.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	rise