

LOCATION 1511 Elkhart Cir. CITY Gastonia
 BETWEEN Oldwell Ln. STREET & Colony Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>102'</u>	<u>1-17-2001</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>62'</u>	<u>"</u>		

ENTERS 1511 Elkhart Cir. BRANCHED INTO Ø
 TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES WC LOCATION 263' west


PRESSURE TEST @ 160 PSI FOR 1/4 HRS BY D.C. center of Elkhart Cir.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3' FT 0" IN LOCATION 19' south of center of Elkhart Cir.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 00017260

REMARKS New 3/4" Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>