

LOCATION 1524 EIKHART CIR. CITY GASTONIA

BETWEEN Hoffman Rd. STREET & EIKHART CIR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>50'</u>	<u>7-26-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>			

ENTERS 1524 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 356' N. of center of EIKHART CIR.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 19' W. of center of EIKHART CIR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 656901

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	