

LOCATION 1527 Elkhart Cir CITY Gastonia  
BETWEEN Hoffman Rd STREET & Elkhart Cir STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
Service TO BLDG	3/4"	P	50'	9-27-00		
Service TO PROP LINE	3/4"	P	0'			
PROP LINE TO BLDG	3/4"	P	50'			

ENTERS Same

BRANCHED INTO

TAP SIZE 3/4"

PRESSURE 100

PSI

INCHES W.C.

LOCATION

56' East of Elkhart

Cir & 521 N. of Elkhart Cir

PRESSURE TEST @

100

PSI

FOR

1/4

HRS

BY

B. Ballard

3/4"

SIZE

3/4"

C I

BARE STEEL

COATED STEEL

PLASTIC ☒

YEAR INSTALLED

2000

DEPTH

2 FT

IN

LOCATION

56' East of Elkhart Cir

"A" P/S READING

Plastic

TOTAL ANODES 1#


17#

LR #

00896695

REMARKS

New Plastic Service.



Test Station		
Reading & location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	