

LOCATION 1559 EILWART CIRCLE CITY GA. ASTONIA
BETWEEN Old Well Ln. STREET & Colony Woods Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>65'</u>	<u>11.27.01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>5</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>60'</u>			

ENTERS 1559 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION S. of 1559

PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY GL

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT IN LOCATION S.W. of cul de sac

"A" P/S READING N/A TOTAL ANODES 1# 17# LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	

