

LOCATION 1562 Elkhardt Cir. CITY Gastonia
 BETWEEN Old well Ln. STREET & Hoffman Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>102'</u>	<u>2-12-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>42'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>60'</u>	<u>"</u>		

ENTERS 1562 Elkhardt Cir. BRANCHED INTO Ø
 TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 452' West


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY center of Elkhardt Cir.
D.R.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 2' FT 0" IN LOCATION 20' south of center of Elkhardt Cir.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø L R # 94077

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>