

COPY

LOCATION 1595 ELKHART Circle CITY EASTONIA

BETWEEN HOFFMAN Rd. STREET & ELKHART Circle STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>PLASTIC</u>	<u>70'</u>			
MAIN TO PROP LINE	<u>5/8"</u>	<u>PLASTIC</u>	<u>8'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>PLASTIC</u>	<u>62'</u>			

ENLERS 1595 BRANCHED INTO 0

TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 109' N of C of ELKHART Cir.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 6 IN LOCATION 20' W of C of ELKHART Circle

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 17# LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>0.55V</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>0.55V</u>

