

LOCATION 1628 Elkhart Cir CITY Creston, IA
 BETWEEN Oldwell Ln. STREET & Colony Woods Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>83'</u>	<u>6-25-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>7'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>76'</u>	<u>"</u>		

ENTERS 1628 BRANCHED INTO Ø
 TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 8' west of center of Elkhart Cir. Cukl.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
 MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
 DEPTH 3' FT 0" IN LOCATION 40' north of center of Elkhart Cir. Cukl. as ac.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # A0497776

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead White Existing Main	E	rise