

LOCATION 1633 Elkhardt Cir. CITY Grassboro
BETWEEN Old Well Ln. STREET & Colony Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	110'	3-26-63		
MAIN TO PROP LINE	5/8"	P	42'	"		
PROP LINE TO BLDG	5/8"	P	68'	"		

ENTERS 1633 BRANCHED INTO 0
TAP SIZE 3/4" PRESSURE 60 PSI INCHES WC LOCATION 251' East


PRESSURE TEST @ 100 PSI FOR 14 HRS BY Woods

MAIN-SIZE 2" C I 0 BARE STEEL 0 COATED STEEL 0 PLASTIC ✓ YEAR INSTALLED 1992

DEPTH 3' FT 0" IN LOCATION 20' north of Elkhardt Cir.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # A0121971

REMARKS New Plastic Service (Ld. Bore)



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	<u>0.12</u>
P/S Pipeline Lead White Existing Main	E	<u>0.12</u>