

LOCATION 1639 Elkhart Cir. CITY Gastonia  
BETWEEN Elkhart Cir. STREET & Hoffman Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	75'	5-07-01		
MAIN TO PROP LINE	3/4"	P	8'	"		
PROP LINE TO BLDG	3/4"	P	65'	"		


ENTERS 1639 BRANCHED INTO Ø  
TAP SIZE 1/2" PRESSURE 60 PSI INCHES WC LOCATION 347' N.E. of

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY center of Elkhart Cir.  
D. Woody

MAIN-SIZE 2" C I Ø BARE STEEL Ø COATED STEEL Ø PLASTIC ✓ YEAR INSTALLED 1999  
DEPTH 2 FT 6" IN LOCATION 39' East of center of Culd# 3AC.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 00312471

REMARKS New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic rise
P/S Pipeline Lead - White Existing Main	E	