

LOCATION 1908 E Elm St CITY GASTONIA  
BETWEEN GROVER ST STREET & DEADEND STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PL</u>	<u>158'</u>	<u>7-11-98</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>142'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>16'</u>			


ENTERS: 1908 BRANCHED INTO: 1909 & 1910 E Elm St  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL / PLASTIC \_\_\_\_\_ YEAR INSTALLED 1965  
DEPTH: 2 FT 0 IN LOCATION

"A" P/S READING .85 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: - Tied-over 1909 & 1910 to 3/4 Plastic Service - Found Dresser  
Coupling & Bonded pipe - C.P. Reading 1.0 - These ARE NOW Isolated  
Services

\*Note: 1910 Already Isolated Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>Plaste</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY