

LOCATION 3804 EMERALD LN. CITY GASTONIA
BETWEEN Regis Dr. STREET & Lead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC 86'</u>		<u>8-25-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC 22'</u>				
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC 64'</u>				

ENTERS 3804 BRANCHED INTO 0

TAP SIZE 3/8" PRESSURE 60 PSI INCHES W.C. LOCATION 262' S of C of
St. Regis Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1970

DEPTH 3 FT 0 IN LOCATION 10' W of C of Emerald LN.

"A" P/S READING -85 TOTAL ANODES 1# 0 17# 0 LR # 0756489

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>