


LOCATION 3808 Emerald Ln.CITY GASTONIABETWEEN St. Regis Dr.STREET & End of Emerald Ln.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>185'</u>	<u>1-3-74</u>	<u>170' Existing 3/4 CW</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>20'</u>		<u>Pipe.</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>165'</u>			

ENTERS: 3808BRANCHED INTO: 0TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 408' S of C of St Regis Dr.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL.MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1967DEPTH: 3 FT. 6 IN. LOCATION 13' W of C of Emerald Ln."A" P/S READING: 1.1 TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_REMARKS: Retired & Renewed 3/4 CW leaking Service.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY