

LOCATION 417 Apartments + 418 S. Emerson CITY GASTONIA
 BETWEEN Garrison Blvd. STREET & 4th Ave. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>	<u>11-5-94</u>	<u>Tied over</u>	<u>13' Existing 3/4</u>
MAIN TO PROP. LINE					<u>HW on 417</u>	
PROP. LINE TO BLDG.					<u>Tied over 142</u>	<u>Exist 3/4 P. 80 418</u>

 ENTERS: 417 S. Emerson BRANCHED INTO: 417 S. Emerson Split 417 Comes OFF 418
 TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 138' N of Cor 4th Ave

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993
 DEPTH: 3 Ft. 0 In. LOCATION 17' E of Cor S. Emerson St.

"A" P/S READING Plastic TOTAL ANODES 1* 0 17* 0 L.R. # 498 310

REMARKS: 418 S. Emerson Comes OFF 417 3/4 HW Service.
Tied Both Services over to New 2" Plastic Main



Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	S	<u>417 Riser 1.5</u> <u>418 Riser Plastic</u>	
P/S Pipeline Lead - White Existing Main	E		