

LOCATION 1424 Emily Ct.CITY BASTONIABETWEEN OAK HollowSTREET & End OF Culdesack

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>128'</u>	<u>11-22-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>78'</u>			


ENTERS. 1424BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60

PSI

INCHES W.C.

LOCATION 78' E of Prof OAK HollowPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RLMAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1984DEPTH: 3 FT. 6 IN LOCATION 26' S of Prof Emily Ct."A" P/S READING Plastic N/ATOTAL ANODES 1# 0 17# 0L.R. # 681330

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY