

LOCATION 2338 Erika Ct. CITY Castroville  
BETWEEN Hamptonbrook Dr. STREET & Morgan Ct. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>138'</u>	<u>9-27-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>93'</u>			

ENTERS. 2338 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 PSI          INCHES W C LOCATION 147' N. of center of Hamptonbrook Dr

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY S. Huffstetter  
MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED           
DEPTH: 3 FT 0 IN LOCATION 19' W. of center of Erika Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 645206

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY