

LOCATION 1121 Essex St. CITY Dorchester
BETWEEN Apple Blossom STREET & Glen St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>		<u>Renewed 6-3-94</u>	<u>Tried over</u>	<u>21' Existing 3/4</u>
MAIN TO PROP. LINE					<u>Plastic Pipe</u>	<u>To new 2"</u>
PROP. LINE TO BLDG.					<u>Plastic Gas</u>	<u>Main</u>

ENTERS: 1121 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 81' E of C of Apple Blossom

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT 0 IN LOCATION 13' S of C of Essex St.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY