

LOCATION 1137 Essex St CITY GASTONIA

BETWEEN Apple Blossom STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>		<u>orig. Inst.</u>	<u>Tied over</u>	<u>50' Existing</u>
MAIN TO PROP. LINE				<u>4-5-85</u>	<u>3/4 P. Pipe</u>	<u>To New 2"</u>
PROP. LINE TO BLDG.					<u>Plastic GAS</u>	<u>Main</u>

ENTERS. 1137 BRANCHED INTO: 0

TAP SIZE. 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 110' w of Caf Apple Blossom


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 6 IN LOCATION 13' S of Caf Essex St

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 I.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY