

LOCATION 1144 Essex St CITY Gastonia  
BETWEEN Apple Blossom Circle STREET & Scruggs St STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>			<u>Tied over 70' Existing 3/4</u>	
MAIN TO PROP. LINE					<u>CW. Pipe To New 2"</u>	
PROP. LINE TO BLDG.					<u>Plastic Main</u>	

ENTERS: 1204 Essex BRANCHED INTO: 1144 Essex  
TAP SIZE: 3/4 Straight PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 299' W of Apple Blossom Circle  
D. Tee

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL  
MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1996  
DEPTH: FT IN LOCATION 78' N of E of Essex St.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>1.0</u>

ENG. DEPT. USE ONLY