

LOCATION 1215 Essex Ave. CITY Gastonia
BETWEEN Glennst. + W WARE STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>72'</u>	<u>6-15-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>67'</u>			

ENTERS 1215 Essex Ave. BRANCHED INTO _____
TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W/C LOCATION 12' S. Center
Essex. 465' W. Appie

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY CR Blossom

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH. 3 FT 6 IN LOCATION 12' S. of Center Essex Ave.

"A" P/S READING N/A TOTAL ANODES 1# — 17# — L.R. # —

REMARKS Ran new 3/4" Plastic service to 1215 Essex Ave.

