

LOCATION 1083 Fairfield Dr CITY Gastonia
BETWEEN Clinton STREET & Maple STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>107'</u>	<u>12-4-98</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>100'</u>			


ENTERS: 1083 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 19' N. of e of Fairfield

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1974

DEPTH: 3 FT 0 IN LOCATION _____

"A" P/S READING 1.60 TOTAL ANODES 1# ✓ 17# _____ L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY